


IAPMO OCEANIA

7-11 Fullard Road, Narre Warren, Victoria 3805, Australia /info@iapmooceania.org



CERTIFICATE OF CONFORMITY

IAPMO Oceania hereby grants to:

Aliaxis UK

A.B.N.:

St Peters Road, Huntingdon, Cambridgeshire PE29 7DA United Kingdom

Email: David.cousins@alixaxis.com

the right to use the WaterMark in accordance with the ABCB Manual for the WaterMark Certification Scheme;– Australian Standards; WaterMark Technical Specifications; and the Plumbing Code of Australia; only in respect of the certified product as described in the WaterMark Certificate of Conformity – Schedule of Certified Product (Refer also IAPMO Product Listing Directory). The Certificate is granted subject to the rules governing the WaterMark Certification Scheme and the Terms and Conditions of the Approved User Agreement and IAPMO Oceania's WaterMark Governance Rules.

Evaluated to:

AS/NZS 4936-2002

Air admittance valves (AAVs) for use in sanitary plumbing and drainage systems

Manufacturer:

Refer to Licence Holder

Licence No.: WM-022830

First Certified: 31 Jul 2018

Certification Date: 31 Jul 2026

Expiry Date: 30 Jul 2031

David Viola

Chief Executive Officer of the IAPMO Group

This WaterMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO Oceania, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO Oceania. This certificate can only be reproduced in its entirety. Any alteration of this certificate could be grounds for revocation of this certification.

"This certificate is issued by a JAS-ANZ accredited Conformity Assessment Body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate."



WATERMARK CERTIFICATE OF CONFORMITY

SCHEDULE OF CERTIFIED PRODUCT



Certificate Holder
Aliaxis UK

A.B.N.:

St Peters Road, Huntingdon, Cambridgeshire PE29 7DA United Kingdom

Manufacturer
Refer to Licence Holder

Standard
AS/NZS 4936-2002

Air admittance valves (AAVs) for use in sanitary plumbing and drainage systems

Licence No. WM-022830

Certification Date: 31 Jul 2026

Expiry Date: 30 Jul 2031

First Certified: 31 Jul 2018

Brand Name	Model Name	Model ID	Product Type	Product Description	End Connection	Rated Capacity	Flow Rate	Material
Studor	Mini-Vent	49017, 49018	Air admittance (induct/one way)	DN 32 Air Admittance Valve	Flexible push-fit	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Mini-Vent	49009, 49010, 49018	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Mini-Vent	49017, 49018	Air admittance (induct/one way)	DN 50 Air Admittance Valve	Flexible push-fit	94 Fixture Units (Group)	7.5 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 32 Air Admittance Valve	Flexible push-fit	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Redi-Vent	49202	Air admittance (induct/one way)	DN 50 Air Admittance Valve	Flexible push-fit	10 Fixture Units (Group)	2.4 L/s	ABS
Studor	Maxi-Vent	49112	Air admittance (induct/one way)	DN 80 Air Admittance Valve	Flexible push-fit	1728 Fixture Units (Group) 125 Fixture Units (Stack)	32 L/s	ABS
Studor	Maxi-Vent	49112	Air admittance (induct/one way)	DN 100 Air Admittance Valve	Flexible push-fit	1728 Fixture Units (Group) 125 Fixture Units (Stack)	32 L/s	ABS
Studor	Tec-Vent	49209	Air admittance (induct/one way)	DN 40 Air Admittance Valve	R1-1/2	94 Fixture Units (Group)	7.5 L/s	Flame retardant polycarbonate (unverified)

A handwritten signature in black ink, reading "David Viola". The signature is written in a cursive style with a large initial "D" and "V".

David Viola
Chief Executive Officer of the IAPMO Group